## ift-Nachweis



Number	20-004059-PR06 (NW-K05-06-en-01)	Basis *) EN 17333-5:2020-03
Owner	Hilti Entwicklungsgesellschaft mbH Hiltistr. 6 86916 Kaufering Germany	EN 12667:2001-01 *) and corresponding national versions (e.g. DIN EN) Test report: 20-004059-PR04 PB- K05-06-de-01
		Representation
Product	One compound foam	and the second
Designation	Hilti CF I 750	
Details	Material Polyurethane (PU) foam, based on 4,4'- diphenylmethandiisocyanate, isomer and homologue; Blow- ing agent Dimethylether, propan, isobutane and butan; Colour Grey; Dimension (W x L) in mm 500 x 500; Thickness in mm app. 50 (single board app. 25); density in kg / m <sup>3</sup> app. 13 – 15	
Conditioning	Samples were pre conditioned at 70°C for 21 days. The samples were then conditioned at 23 °C and 50 % RH.	Instructions for use
Special features	Multiple samples were stapled to get the thickness of the sample. The samples have uneven surfaces due to the manufacturing process.	as evidence in accordance with the above basis. Validity There is no time limit.
Result		When using this document the up-

Thermal conductivity (mean value) according to EN 17333-5:2020-03



 $\lambda = 0.036 \text{ W/(m \cdot K)}$ 

\* The thermal conductivity was determined at a mean temperature of 10°C.

ift Rosenheim 26.02.2021

Manuel Demel, M.BP, Dipl.-Ing. (FH) Deputy Head of Testing Department **Building Physics** 

Monvel Dame Round Hulo.

Konrad Huber, Dipl.-Ing. (FH) Operating Testing Officer **Building Physics** 

Identity-Check



www.ift-rosenheim.de/ift-geprueft ID: 895-792BA

Contact Phone: +49 8031 261-0 Fax: +49 8031 261-290 www.ift-rosenheim.de

Testing and Calibration – EN ISO/IEC 17025 Inspection – EN ISO/IEC 17020 Product Certification – EN ISO/IEC 17065 Certification of Management Systems – EN ISO/IEC 17021



**DAkkS** Akkreditierungsstelle D-PL-11349-01-00

to-dateness of above basis and the conformity of the product have

The data and results given relate

solely to the tested/described specimen. This test/evaluation does not allow any statement to

be made on further characteristics of the present structure regarding performance and quality. Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

to be observed.